



1001 N. Fairfax St., Suite 503 • Alexandria, VA 22314
703-312-4200 • F: 703-312-0065

www.iiar.org

INTERPRETATION: IIAR SC 2018-1

SUBJECT: Flexible Connectors for Relief Piping

QUESTION: Are flexible hose connections sufficient to serve as connective piping between relief valve outlets and the associated relief discharge header piping?

ANSWER:

Yes, flexible hose connections could comply with ANSI/IIAR 2-2014 in this type of application.

COMMITTEE ACTION: None